


(ODA) SZ - Svježi zrak
 (SUP) DZ - Dobava
 (EHA) OZ - Otpadni zrak
 (ETA) PZ - Odsisni zrak
 (RCA) RZ - Opto ni zrak
 (MA) MZ - Pomiješani zrak

Dobava	THOR TB2		Masa	94 kg		Projekt broj	119-1579		Dodatno ime objekta	Poz.br.
Protok zraka	m ³ /h	6.370	Količina	1		Merilo	1:21		OB VARAŽDIN-URE ENJE PROSTORA LJEKARNE	
Grijanje I	kW	21,81	Ime	V.Stojanovic		Datum	13.6.2019.		BE:	KANALNI GRIJKA ZA ODVLAŽIVANJE
			Aircal++	Verzija		3.20.166		AB NR:	Vrsta projekta	Ponuda
			Program	Verzija		3.20.166 / 49.1		Debljina oplata	50,0 mm	
			Ispisano	13.6.2019.		Interna brojka			Šifra crteža	Napajanje
						Tip		KEK 5-M-LU50S-H		
						Model				